

ENGINEERING DEPARTMENT
Town of Poughkeepsie

PETER D. SETARO, P. E.

Town Engineer

DONALD A. BEER

Associate Town Engineer

SEAN CRIMMINS

Assistant Town Engineer

PETER HOBDAY

Assistant Town Engineer

ONE OVEROCKER ROAD
POUGHKEEPSIE, NY 12603

TEL # (845) 790-4736

TEL # (845) 790-4748

TEL # (845) 790-4747

**FULL CIPP SANITARY SEWER PIPE REPAIRS
FOR THE TOWN OF POUGHKEEPSIE**

CONTRACT 2018-02

Addendum No. 2

June 7, 2018

The following are questions that were asked from a potential bidder. The questions and answers are listed below. This will be the last Addendum for this Bid.

- 1 Most lining operations will exceed the "normal" work hours given. Will the contractor be charged for any work before 7am or after 3pm? If yes, what is the cost?

If work exceeds the hours given and there is an emergency that warrants the Town of Poughkeepsie Sewer Department involvement, the contractor could be charged the hourly rate for two (2) staff persons @ \$200/hr. Additional charges could apply if more staff person are needed.

- 2 Will water be made available free of charge?

Yes

- 3 Are there any pump stations that will effect the bypass for the lining work?

There is a force main discharge at MH 310 on Lindbergh Pl, upstream of MH 291 on Maple Rd as depicted on the "Sheet 112 and 128" Area Map. Time may be limited to 4 hours if blockage of all the flow entering MH 291 (downstream MH of pipe repair) is required.

- 4 Will the Town provide truck access to the man holes to be lined?

The contractor is responsible for Traffic Maintenance and Protection. However the Town will assist in manhole location and allow truck access within Town owned easements.

End of Addendum No. 2 text