

ENGINEERING DEPARTMENT
Town of Poughkeepsie

PETER D. SETARO, P. E.

Town Engineer

DONALD A. BEER

Associate Town Engineer

SEAN CRIMMINS

Assistant Town Engineer

PETER HOBDAY

Assistant Town Engineer

ONE OVEROCKER ROAD
POUGHKEEPSIE, NY 12603

TEL # (845) 790-4736

TEL # (845) 790-4748

TEL # (845) 790-4747

**CIPP LATERAL TAP REPAIRS – 2017
FOR THE TOWN OF POUGHKEEPSIE**

CONTRACT 2017-03

Addendum No. 1

June 13, 2017

It came to our attention that there was some confusion with the CIPP lateral repair bid specifications.

The repairs in this bid are to seal the connection point of the lateral and the main pipe to prevent groundwater from entering the system. The main pipe is 8" diameter and made of AC transite material. Only the first few feet of the lateral from the main pipe is anticipated to need lining.

These type of CIPP lateral repairs have been referred to as "Top Hats" or "Shorty T Liners" in the industry.

Links for the TV Inspection videos, the associated reports and the itemized outline of the repairs are available on the Town of Poughkeepsie's website bid page located at:

<http://www.townofpoughkeepsie.com/bids/index.html>

End of Addendum No. 1 text