

ENGINEERING DEPARTMENT
Town of Poughkeepsie

PETER D. SETARO, P. E.

Town Engineer

DONALD A. BEER

Associate Town Engineer

SEAN CRIMMINS

Assistant Town Engineer

PETER HOBDAY

Assistant Town Engineer

ONE OVEROCKER ROAD
POUGHKEEPSIE, NY 12603

TEL # (845) 790-4736

TEL # (845) 790-4748

TEL # (845) 790-4747

**MANCHESTER GARDENS SEWER MANHOLE REPLACEMENT AND
STREAM RELOCATION – 2017**

FOR THE TOWN OF POUGHKEEPSIE

CONTRACT 2017-04

Addendum No. 1
September 7, 2017

These questions came to our attention from a potential bidder. They are answered as they were received:

- How many gallons for sewage were you anticipating?

*It is anticipated that **peak sewer flows** during dry weather conditions could possibly reach a flow rate of 1.2 million gallons per day (765 gpm).*

- Franco said that he was going to supply some pipe; was it the 48" for the stream diversion or the 18" SDR?

The Town of Poughkeepsie Sanitary Department will provide 120 linear feet of 48" diameter dual walled HDPE pipe for the temporary stream diversion bypass pipe.

End of Addendum No. 1 text