

BUILDING DEPARTMENT

Town of Poughkeepsie

LEONARD J. SPLAIN-FIRE INSPECTOR
ONE OVEROCKER ROAD
POUGHKEEPSIE, NY 12603

PHONE (845) 485-3659
FAX (845) 486-7888
FAX (845) 486-7881

MEMO

To: Fire Prevention Bureau

From: Leonard J. Splain

Date: 5/9/18

Re: May 8/2018 Fire Prevention Bureau Meeting

In attendance Jeff Renihan, Matthew Woolever, Bruce Flower, George Finn.

Received complaint 2170 South Rd. fire department access and FD Connection not accessible.

Received complaint 2170 South Rd. employees possibly sleeping in building under renovation.

Received Complaint 2611-2629 South junk being dumped on site.

Fire Prevention Code needs to be updated with regard to issuing permits for recreational fires.

C & C complaint from NHFD previous meeting has been completed, smoke heads changed to rate of rise/ heat should resolve false alarms.

Possible problem with reoccurring alarms at another hair salon, (1 -2 recent alarms) not sure what was the cause at this point, at 2001 South that needs to be watched in case corrective action needs to be taken.

Concern expressed for State Hospital grounds, building is being secured by professional company and fencing being installed at fire scene.

Property Maintenance Inspections and Fire Safety Inspection status, 3 year and 1 year inspections being tracked via spread sheet, Input into computer system and able to be viewed on Munis.

Letter will be coming from Fire Prevention Bureau, to the town board, in support of a new address numbering system-proposed by George Finn- everyone has agreed to support.

Next Meeting 6/5/18 1 Overocker Rd. Down stairs meeting room.

