

BUILDING DEPARTMENT

Town of Poughkeepsie

LEONARD J. SPLAIN-FIRE INSPECTOR
ONE OVEROCKER ROAD
POUGHKEEPSIE, NY 12603

PHONE (845) 485-3659
FAX (845) 486-7888
FAX (845) 486-7881

MEMO

To: Memo

From: Leonard J. Splain, Fire Inspector

Date: 10/3/18

Re: Fire Prevention Bureau October 2018 Minutes

- 1- In attendance on 10/2/18, George Finn- AFD , Michael Conroy-FFD, Jeff Renihan-NHFD, Lenny Splain- Fire Inspector.
- 2- 2611 South Rd Fire hydrant found out of service at recent structure fire on 9 / 24/18 rear of property. Property vacant for a few years and some confusion as to who owned hydrant.
- 3- On 3/25/18 Order to Remedy 40-18 sent to property owner UPS Capitol Business Credit to restore and maintain hydrant on property.
- 4- Arlington Fire Department Requests from Building Department annual Private Hydrant inspection reports that we have on file.
- 5- Compliance Engine.com discussed again, possibly to have a presentation at one of our Fire Preventions Meetings. This company can track all required test/inspection reports.
- 6- Confusing Numbering at 64 Ireland Drive Extension, found the number 60 on the building during recent inspection. Working with George Finn talking to Jeffery Dykstra Dutchess 911 numbering if fix is needed.
- 7- Report from AFD hydrant found out of service Amber Ct. Need to contact Spinniker Mgmt. for fix.
- 8- AFD noted, 50 K grant for various education and equipment.
- 9- AFD on going Addressing Scheme update being worked on.
- 10- Arlington Fire District, Fairview Fire District and New Hamburg Fire District noted fire safety month.
- 11- Open House at Fairview Fire House on October 27 noted.
- 12- 275K Paramedic Grant Received for Fairview FD. Noted.
- 13- Next meeting 11/13/18 at 03:00pm at lower level meeting rm. 1 Overocker Rd., Town of Poughkeepsie Town Hall.