

## Carol Barone

---

**From:** Andoh, John <jandoh@dutchessny.gov>  
**Sent:** Tuesday, November 21, 2017 11:35 PM  
**To:** Carol Barone  
**Subject:** Comments on MacDonnell Heights Town Center  
**Attachments:** DR - 1 Town Center.docx


Good evening,

May I please forward my comments on MacDonnell Heights Town Center to you?

Please see attached.

**John C. Andoh, CCTM, CPM**  
**Dutchess County Transit Administrator**  
**Dutchess County Public Transit**  
14 Commerce Street  
Poughkeepsie, NY 12603  
Phone: (845) 473-8521  
Cell: (845) 264-2355  
Fax: (845) 473-8643  
Public Transit Information Line: (845) 473-8424  
Email: [jandoh@dutchessny.gov](mailto:jandoh@dutchessny.gov)  
<http://www.dutchessny.gov/PublicTransit>

MARCUS J. MOLINARO  
COUNTY EXECUTIVE



ROBERT H. BALKIND, P.E.  
COMMISSIONER

JOHN C. ANDOH, CCTM, CPM  
COUNTY TRANSIT ADMINISTRATOR

## COUNTY OF DUTCHESS

DEPARTMENT OF PUBLIC WORKS  
DIVISION OF PUBLIC TRANSIT

### DEVELOPMENT REVIEW COMMENTS 17-01

TO: Janet Tissiere, Junior Planner

FROM: John Andoh, Dutchess County Public Transit Administrator

DATE: November 21, 2017

SUBJECT: MacDonnell Heights Town Center

---

I have completed my review of the MacDonnell Heights Town Center and I would recommend that the proposed developer consider the following conditions within the project:

- On both sides Dutchess Turnpike, to include a bus shelter with trash receptacle, bench, map case and solar powered lighting in the turnout near Buildings E and H.
- A pole should be placed to allow for placement of a bus stop sign which would be attached by the County.
- The bus turnout should follow the specifications as defined below to ensure that a 40 foot bus can enter and exit the turnout safely.
- This project is served by Dutchess County Public Transit Route D, Monday through Saturday.
- There should be sidewalk access along Dutchess Turnpike from Barnes Drive to Victory Lane and Darrow Place to Concord Village Drive with curb cuts that meet Americans with Disabilities Act (ADA) requirements.

Should you have any questions regarding this memorandum, please contact me by calling 845.473.8521 or via email to [jandoh@dutchessny.gov](mailto:jandoh@dutchessny.gov).


Thank you.



**COUNTY OF DUTCHESS**

DEPARTMENT OF PUBLIC WORKS  
DIVISION OF PUBLIC TRANSIT

**Figure 8. Parallel Bus Bay**



Not to Scale.

Acceleration and Deceleration Lane Dimensions			
Through Speed (mph)	Acceleration Lane Length (feet)	Deceleration Lane Length (feet)	Entrance and Exit Taper Length (feet)
35	250	184	170
40	400	265	190
45	700	360	210
50	975	470	230
55	1400	595	250
60	1900	735	270

Source: TCRP 19: Guidelines for the Location and Design of Bus Stops.